



CERTIFICATE OF APPROVAL

No CF 5516

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ALLGOOD LTD

63-83 Brearley street, Birmingham, B19 3NT United Kingdom
Tel: 0121 359 4415

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

**Panic Exit Devices and Exit
Pad Emergency Exit Devices
and Associated Accessories**

TECHNICAL SCHEDULE

**TS26 The Contribution of Panic
Exit Devices to the Fire
Resistance of Door Assemblies**

**TS31 The Contribution of
Emergency Exit Devices to the
Fire Resistance of Door
Assemblies**

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager

Issued: 13th March 2017
Reissued: 10th June 2026
Valid to: 11th March 2031





CERTIFICATE No CF 5516

ALLGOOD LTD

1. This approval relates to the Allgood series of panic and emergency exit device and associated accessories as detailed within this certificate. The devices are generally all surface fixed.
2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This approval relates to the use of the family of exit devices with the following door assemblies:-

Code ITT - Previously proven unlatched, 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code MM* - Previously proven unlatched, 20 to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM* - Previously proven unlatched, 20 to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

* See separate table of performance within Items 12, 13 and 14 for limitations on push pad, motorised, and micro-switched units

4. It is assumed that where panic hardware with motorised and/or micro-switch function are required the door manufacturer has suitable fire test evidence or certification for the required classification period with a suitable concealed or surface mounted cable loop, as required.
5. The exit devices are approved on the basis of:
 - i) Initial type testing to EN 1125 and EN 179 for mechanical properties
 - ii) An appraisal against TS26 and TS 31
 - iii) Certification of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) On-going audit testing in accordance with TS26 and TS 31 requirements

Page 2 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

6. It is a requirement of this report that the doorsets to which the panic hardware is fitted shall have been previously tested unlatched in the configuration required.
7. The purpose of the appraisal is only to consider the influence of fitting the proposed hardware items to a doorset, and not its ability to provide an essential latching action.
8. ITT30 and 60 timber doorsets shall be installed in accordance with BS 8214.
9. This approval is applicable only to the specified exit devices and relevant accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1) which have previously been successfully tested unlatched in the configuration required, but shall be fitted with a CERTIFIRE approved door closer. Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.
10. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.
11. All door hardware is subject to the acceptance by the chosen door assembly supplier's tested, assessed or certificated scope, which generally identifies the types of hardware approved, the required specification/design based on the key materials/maximum size (e.g. case size etc.), and the application of any additional intumescent protection.

On this basis approval should be sought from the specific door assembly supplier to ensure compliance based on this assessed/certificated scope.


Page 3 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

12. The following table shows acceptable doorsets types and fire resistance periods for all units with the exception of push pad, motorised, and micro-switched units:

	Approved Door Type			
Class	IMM	MM	ITT	ITM
BS476-22				
FD20	✓	✓	✓	✗
FD30	✓	✓	✓	✗
FD60	✓	✓	✓	✗
FD90	✓	✓	✓	✗
FD120	✓	✓	✓	✗
FD240	✓	✓	✗	✗
EN1634-1				
Integrity only	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗
Integrity/insulation	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗

Key:

- ✓ - Approved
✗ - Not approved

Page 4 of 9 Signed 
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

13. The following table shows acceptable doorsets types and fire resistance periods for XX10293SS, XX10293, XX10294SS & XX10294 Push Pad series:

	Approved Door Type			
Class	IMM	MM	ITT	ITM
BS476-22				
FD20	✓	✓	✓	✗
FD30	✓	✓	✓	✗
FD60	✓	✓	✓	✗
FD90	✓	✓	✓	✗
FD120	✓	✓	✓	✗
FD240	✓	✓	✗	✗
EN1634-1				
Integrity only	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗
Integrity/insulation	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗

Key:

- ✓ - Approved
- ✗ - Not approved

Page 5 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

14. The following table shows acceptable doorsets types and fire resistance periods for XX9328S, XX9328, XX9329S & XX9329 Series with MOT Motorised function or MC Micro-switch function:

	Approved Door Type			
Class	IMM	MM	ITT	ITM
BS476-22				
FD20	✓	✓	✓	✗
FD30	✓	✓	✓	✗
FD60	✓	✓	✓	✗
FD90	✓	✓	✓	✗
FD120	✓	✓	✓	✗
FD240	✓	✓	✗	✗
EN1634-1				
Integrity only	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗
Integrity/insulation	IMM	MM	ITT	ITM
20	✓	✓	✓	✗
30	✓	✓	✓	✗
60	✓	✓	✓	✗
90	✓	✓	✓	✗
120	✓	✓	✓	✗
240	✓	✓	✗	✗

Key:

- ✓ - Approved
- ✗ - Not approved

Note: The approval for assumes that the door manufacturer has suitable fire test evidence for the required classification period for a suitable concealed or surface mounted cable loop.

Page 6 of 9 Signed 
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

15. Doors are classified as the following types:

Code ITT - 20 minute to 60 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code ITM - 20 minute to 60 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in steel frames.

Code MM - 20 to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 120 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Scope of Approval:

This approval relates to the following items in the Allgood.Panic and Emergency Exit Devices and associated accessories:

EN1125 PANIC EXIT HARDWARE	
DESCRIPTION	Allgood Ltd
Push bar 1 locking point satin stainless steel plated	XX10292SS
Push bar 1 locking point silver grey finish	XX10292
Push bar 3 locking point satin stainless steel plated	XX10290SS
Push bar 3 locking point silver grey finish	XX10290
Touch bar satin stainless steel plated panic latch	XX9325SS
Touchbar silver finish panic latch	XX9325
Touch bar satin stainless steel plated 3 point vertical rod panic bolt	XX9320S
Touchbar silver finish 3 point vertical panic bolt	XX9320

EN1125 PANIC EXIT HARDWARE	
DESCRIPTION	Allgood Ltd
Grade 316 satin stainless steel panic latch	10392
Grade 316 satin stainless steel 3 point vertical panic bolt	10390
Touchbar grade 316 satin stainless steel panic latch	9425
Touchbar grade 316 satin stainless steel 3 point vertical panic bolt	9420

Page 7 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516

ALLGOOD LTD

EN1125 PANIC EXIT HARDWARE – MOTORISED & MICROS-SWITCH	
DESCRIPTION	Allgood Ltd
Motorized Touch satin stainless steel plated panic latch	XX9328S
Motorised Touchbar silver finish panic latch	XX9328
Motorized Touch bar satin stainless steel plated 3 point vertical rod panic bolt	XX9329S
Motorised Touchbar silver finish 3 point vertical rod panic bolt	XX9329

EN179 EMERGENCY EXIT HARDWARE	
DESCRIPTION	Allgood Ltd
Push PAD 1 locking point satin stainless steel plated	XX10293SS
Push PAD 1 locking point silver grey finish	XX10293
Push PAD 3 locking points satin stainless steel plated	XX10294SS
Push PAD 3 locking points silver grey finish	XX10294
ACCESSORIES	
Horizontal cross arm satin stainless steel plated finish 1150mm	XX10296SS
Horizontal cross arm silver grey finish 1150mm	XX10296A

Page 8 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031



CERTIFICATE No CF 5516 ALLGOOD LTD

Classification codes

The approval provides the following classifications:

XX10292SS, XX10292, XX10290SS, XX10290, XX9320S, XX9320, XX9325S & XX9325 series (push bar to EN1125):

3	7	7	B	1	4	2	2	A	A
---	---	---	---	---	---	---	---	---	---

XX10293SS, XX10293, XX10294SS and XX10294 (push pad to EN179):

3	7	7	B	1	4	4	2	B	A
---	---	---	---	---	---	---	---	---	---

XX9320S, XX9320, XX9325S, XX9325, XX9328S, XX9328, XX9329S & XX9329 Series with motorised variants (touch bar to EN1125) :

3	7	7	B	1	4	2	2	B	A
---	---	---	---	---	---	---	---	---	---

10392, 10390, 9425 & 9420 series (push bar to EN1125)

3	7	7	B	1	4	2	2	A	A
---	---	---	---	---	---	---	---	---	---

Scope of Approval:

- The panic hardware may not be fitted to timber doorsets without perimeter intumescent fire seals within the frame rebate or edge of the door leaf.
- It is a requirement of this report that the doorsets to which the panic hardware is fitted shall have been previously tested unlatched in the configuration required.
- Associated Outside Access Devices (OAD's) are not permitted

Further Information

Further information regarding the details contained in this data sheet may be obtained from Allgood PLC (Tel: 0121 359 4415).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 9 of 9 Signed
E014030-7, E014030-27 &
E014030-28

EWC-QU-FT-733 (Issue 3)

Issued: 11th December 2015
Reissued: 10th June 2026
Valid to: 11th March 2031