



**CONSTRUCTION PRODUCTS REGULATION 2020
DECLARATION OF PERFORMANCE
No. DOP-AGD-150 UKCA**

1. Unique identification code of the product-type:

**9149G, 9150G
door selector**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**9149G, 9150G
door selector**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on double doors and fire and smoke compartmentation doors

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allgood plc
63-83 Brearley Street, Birmingham B19 3NT**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1158:1997 + A1:2002
Notified testing laboratory No.1121 performed the type testing and issued test reports**

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as it has effect in the United Kingdom under the sole responsibility of the manufacturer identified above

**CONSTRUCTION PRODUCTS REGULATION 2020
DECLARATION OF PERFORMANCE
No. DOP-AGD-150 UKCA**

9. Declared performance under harmonised technical specification identified in point 7.

Essential characteristics	Performance
Self closing	
5.1.2	This device has been supplied with all parts necessary for its correct operation
5.1.3	This device enables the correct co-ordination of the door leaves from any opening angle with the use of a carry bar
5.2.1 General	
5.2.2 Closing overload performance	The device withstands a moment of 300N without damage
5.2.3 Manipulation performance	With the leaves closed in the wrong sequence, the operation of the active leaf to a maximum of 40° restores the correct co-ordination operation
5.2.4 Resistance of waiting position	Pass
5.2.6 Damage	Throughout the test program there is no damage to the door co-ordinator device which would adversely affect its performance
5.1.18 Fire / smoke doors	Grade 1: Suitable for use on fire / smoke door assemblies
Durability of Self Closing	Grade 5: 50,000 test cycles
5.2.5 Durability	Grade 3 (96 hours)
5.2.7.1 Corrosion	After being subjected to the spray test the device meets the requirement 'Manipulation performance of clause 5.2.3
5.2.7.2 Corrosion	
Dangerous substances	Pass: the materials in this product do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Stewart Lauder Commercial Director of Allgood plc



63-83 Brearley Street
Birmingham B19 3NT
United Kingdom

01.08.2021