CONSTRUCTION PRODUCTS REGULATION 2020
DECLARATION OF PERFORMANCE
No. DOP-AGD-163 UKCA

1. Unique identification code of the product-type:

XX98171/6 & XX98171S6 Overhead door closers

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

XX98171/6 & XX98171S6 Overhead door closers

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors or on emergency exits

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Allgood plc
63-83 Brearley Street, Birmingham B19 3NT

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 1154:1996 + A1:2002/AC:2006

Notified testing laboratory No.1121 performed the type testing and issued test reports

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as it has effect in the United Kingdom under the sole responsibility of the manufacturer identified above

CONSTRUCTION PRODUCTS REGULATION 2020
DECLARATION OF PERFORMANCE
No. DOP-AGD-163 UKCA

9. Declared performance under harmonised technical specification identified in point 7.

Essential characteristics	**Performance**
Self closing	
5.2.1 General	
5.2.2 Durability	500,000 test cycles
5.2.3 Closing moment	Pass size 2-5
5.2.4 Opening moment	Pass size 2-5
5.2.5 Efficiency	>50% size 2 >65% size 5
5.2.6 Closing time	Pass
5.2.7 Angles of operation	Grade 4, 180°
5.2.8 Overload performance	Pass
5.2.9 Temperature dependence	-15°C to +40°C
5.2.10 Fluid leakage	Pass
5.2.11 Damage	Pass
5.2.12 Latch control	Pass
5.2.15 Adjustable closing force	Pass
5.2.18 Fire / smoke doors	500,000 test cycles
Durability of Self Closing	Grade 3 (96 hours)
5.2.2 Durability	Pass
5.2.17.1 Corrosion	Not applicable
5.2.17.2 Corrosion	
Dangerous substances	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Stewart Lauder – Commercial Director

Date of Issue: 01.08.2021

Allgood plc
63-83 Brearley Street,
Birmingham
B19 3NT