
CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE
No. DOP-AGD-164

1. Unique identification code of the product-type:

XX98181N

**Allgood Hardware Electrically Powered Hold Open & Freeswing
Overhead Door Closer Size 3-4**

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**XX98181S6N & XX98181/6N
Electrically powered hold open & swing free door closer**

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire single leaf and double door leaf doors

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allgood Ltd
63-83 Brearley Street, Birmingham B19 3NT**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

EN 1155:1997 + A1:2002/AC:2006

Notified testing laboratory No.2812 performed the type testing and issued test reports

8. European Technical Assessment

This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as it has effect in the United Kingdom under the sole responsibility of the manufacturer identified above

**CONSTRUCTION PRODUCTS REGULATION 2011
DECLARATION OF PERFORMANCE
No. DOP-AGD-164**

9. Declared performance under harmonised technical specification identified in point 7.

STANDARD DOOR MOUNT PULL SIDE APPLICATIONS

XX98181N Size 3 to 4

Essential characteristics	Performance	Harmonised technical specification
Self closing		
Ability to release		EN 1155:1997+A1:2002/AC:2006
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	24V	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.3 Door closing device requirements	Pass	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass > 65°	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	NPD	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self closing		EN 1155:1997+A1:2002/AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: <i>the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations</i>	

9. Declared performance under harmonised technical specification identified in point 7.

TRANSOM MOUNT PUSH SIDE APPLICATIONS
98181N Size 4

Essential characteristics	Performance	Harmonised technical specification
Self closing		
Ability to release		EN 1155:1997+A1:2002/AC:2006
5.1.2 release from any angle	Pass	
5.1.3 Not possible to inhibit the release	Pass	
5.1.4 Supply voltage	24V	
5.1.5 External electrical connection	Pass	
5.1.6 Inlet for external wiring	Pass	
5.2.1 General	Pass	
5.2.2 Electrical release requirements	Pass	
5.2.3 Door closing device requirements	Pass	
5.2.4 Durability	Pass	
5.2.5 Angle of hold open	Pass > 65°	
5.2.6 Manual release	Pass	
5.2.7 Continuous hold open	Pass	
5.2.8 Overload performance	NPD	
5.2.9 Delayed release	NPD	
5.2.10 Electrical performance	Pass	
5.2.11 Temperature Rise	Pass	
5.2.12 Damage	Pass	
5.2.13 Fire / smoke doors	Grade 1	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self closing		EN 1155:1997+A1:2002/AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.17.1 Corrosion	Grade 3 (96 hours)	
5.2.17.2 Corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: <i>the materials in the door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations</i>	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Stewart Lauder – Managing Director

Date of Issue: 21/01/2026

Allgood Ltd, 63-83 Brearley Street, Birmingham B19 3NT